

- 1) ALL DUCT DIMENSIONS SHOWN ARE IN INCHES UNLESS OTHERWISE SHOWN.
- 2) ALL DUCT DIMENSIONS ARE CLEAR INSIDE DIMENSIONS.
- 3) SEAL AROUND ALL DUCT AND PIPE PENETRATIONS THROUGH NEW WALL WITH FIRE STOP SEALANT SUCH AS GOW CORNING CATALOG #2000 OR EQUAL.
- 4) SEAL AROUND ALL EXISTING OPENINGS IN WALL WITH THE FIRESTOP SEALING COMPOUND SO AS TO BE AIR TIGHT.
- 5) ALL EXISTING DUCT DIMENSIONS TO BE VERIFIED BY FIELD MEASUREMENTS BEFORE COMMENCEMENT OF WORK BY THE CONTRACTOR.
- 6) VERIFY EXISTING DUCT DIMENSIONS IN FIELD. DIMENSIONS SHOWN ARE FROM



Sheet 97 of 112



**THE PORT AUTHORITY
OF NY & NJ**



ORIGINAL SIGNED & SEALED BY
N.Y. P.E. (OR R.A.)

CONFORMED
2/3/98

Ram Communications Consultants, Inc.
10 Woodridge Center Drive
Woodbridge, NJ 07095
(908) 636-6970 fax (908) 636-7260

No.	Date	Revision	Approved

The
World
Trade
Center

12a
STANDBY POWER
5 WORLD TRADE CENTER
COMMUNICATIONS

**HVAC 9th FLOOR
PARTIAL FLOOR PLAN**

This drawing subject to conditions in contract.
All inventions, ideas, designs and methods
herein are reserved to Part Authority and
may not be used without its written consent.

<u>SG</u>	<u>PM</u>	<u>SG</u>
Designed by	Drawn by	Checked by
Date	Scale AS NOTE	
Contract Number	Drawing Number	
WTC-945.071	M-802	